


NOTES:

1. MAINS CONSTRUCTED WITH PVC MUST BE PROPERLY RESTRAINED PRIOR TO INSTALLATION OF THE HDPE TERMINAL CLEAN-OUT.
2. MAINS CONSTRUCTED WITH FUTURE STUB-OUTS, A RWGV MUST BE INSTALLED PRIOR TO THE INSTALLATION OF THE TERMINAL CLEAN-OUT.



STANDARD UTILITY DETAILS
City of Stuart
Utilities & Engineering Department

121 S.W. Flagler Avenue, Stuart, Florida 34994

TERMINAL FLUSHING PORT

DATE: OCTOBER 2021
FILE NAME: 2021 COS Std Details.dwg

SHEET NUMBER
LP-5