



NOTES:

1. MAINS CONSTRUCTED WITH PVC MUST BE PROPERLY RESTRAINED PRIOR TO INSTALLATION OF THE HDPE TERMINAL CLEAN-OUT.
2. MAINS CONSTRUCTED WITH FUTURE STUB-OUTS, A RWGV MUST BE INSTALLED PRIOR TO THE INSTALLATION OF THE TERMINAL CLEAN-OUT.



STANDARD UTILITY DETAILS
 City of Stuart Public Works Department
 121 S.W. Flagler Avenue, Stuart, Florida 34994
 (772) 288-5300

**TERMINAL FLUSHING
 PORT DETAIL**

DATE: OCTOBER 2016
 FILE NAME: 2016 COS LP Details.dwg

SHEET NUMBER
LP-5