



NOTES:

1. SQUARE CONCRETE PAD, OR COARSE GRAVEL UNDER GATE, 8" THICK, 1CU. FT.(TYPICAL).
2. RESILENT WEDGE GATE VALVES SHALL BE USED FOR 2" AND LARGER. 2. NIPPLES (2-1/2 xCLOSE).
3. ALL FITTINGS AND HDPE FROM THE WYE TO LOCKING CAP MUST BE MECHANICALLY RESTRAINED. FOR MAINS 3", 4" AND 6" IN DIAMETER, ONLY MECHANICALLY RESTRAINED PUSH-ON FITTINGS AND PIPE MAY BE USED.
4. APPURTENANCES OF THE ASSEMBLY SHALL BE 2" IN SIZE, UNLESS OTHERWISE SPECIFIED BY THE ENGINEER OF RECORD.
5. CLEANOUT ASSEMBLY INCLUDES ALL APPURTENANCES FROM, AND INCLUDING, THE WYE, TO AND INCLUDING THE CAM LOCK, HAND HOLE, AND FOUNDATION.

	STANDARD UTILITY DETAILS City of Stuart Utilities & Engineering Department	INLINE FLUSHING PORT	
	121 S.W. Flagler Avenue, Stuart, Florida 34994	DATE: OCTOBER 2021 FILE NAME: 2021 COS Std Details.dwg	SHEET NUMBER LP-6