


CITY OF STUART
WASTEWATER CONSTRUCTION NOTES
(CONTINUED)

17. MINIMUM COVER SHALL BE 48 INCHES, PIPES WITH LESS COVER REQUIRE PRIOR APPROVAL OF THE ENGINEER AND CITY OF STUART AND SHALL BE CONSTRUCTED OF DUCTILE IRON PIPE.
18. ALL MANHOLES SHALL HAVE SEWER RAIN GUARDS INSTALLED.
19. THE CONTRACTOR SHALL COMPLY WITH THE FLORIDA TRENCH SAFETY ACT REQUIREMENTS.
20. PRIOR TO ANY TESTING, ALL MAINS 3 INCHES IN DIA. AND LARGER SHALL HAVE A LINE SIZE SWAB PASSED THROUGH THE ENTIRE LENGTH OF THE LINE. NOTE: SWAB SHOULD BE PLACED IN 1st. JOINT OF NEW LINE. END OF MAIN SHOULD BE "TURNED UP" AT 45° AND EXTENDED SO THAT SWABBING AND A FULL BORE FLUSH CAN BE ACCOMPLISHED. BLOW-OFF ASSY. CAN THEN BE PLACED. WHERE LINES BRANCH, SWABS WILL BE PLACED IN BRANCH LINES AND SEQUENTIALLY SWABBED AND FLUSHED.



STANDARD UTILITY DETAILS
City of Stuart
Utilities & Engineering Department

121 S.W. Flagler Avenue, Stuart, Florida 34994

WASTEWATER CONSTRUCTION NOTES

DATE: OCTOBER 2021
FILE NAME: 2021 COS Std Details.dwg

SHEET NUMBER
4