


NOTES:

1. THESE METHODS ARE TO BE USED WHEN INSUFFICIENT COVER EXISTS TO ALLOW PRESSURE PIPE TO CROSS ABOVE CONFLICT PIPE MEETING FDEP VERTICAL SEPARATION GUIDELINES.
2. FITTINGS SHALL BE RESTRAINED WITH RETAINER GLANDS AND OR GRAVITY BLOCKS.



STANDARD UTILITY DETAILS
 City of Stuart
 Utilities & Engineering Department

121 S.W. Flagler Avenue, Stuart, Florida 34994

PRESSURE PIPE CONFLICT

DATE: OCTOBER 2021

FILE NAME: 2021 COS Std Details.dwg

SHEET NUMBER

17