


**NOTES:**

1. BLUE 10 GAUGE THHN WIRE SHALL BE ATTACHED TO THE SERVICE LINE.
2. WHERE SERVICES UNDER PAVEMENT ARE REQUIRED, THE POLYETHYLENE TUBING SHALL BE INSTALLED WITHIN SCHEDULE 40 PVC CASING PIPE.
3. 3/4" & 1" METER SIZES SHALL REQUIRE A LOCKABLE CURB STOP.
4. MINIMUM COVER IN UNPAVED AREAS IS 18", IN PAVED AREAS OR PLANNED ROADWAYS OR SWALES MIN. COVER SHALL BE 36".

**TYPICAL DOUBLE WATER SERVICE CONNECTION**



**STANDARD UTILITY DETAILS**  
 City of Stuart Public Works Department  
 121 S.W. Flagler Avenue, Stuart, Florida 34994  
 (772) 288-5300

**TYPICAL DOUBLE WATER SERVICE CONNECTION**

DATE: OCTOBER 2016  
 FILE NAME: 2016 COS Std Details.dwg

SHEET NUMBER  
**23**