



1. HYDRANT SHALL BE INSTALLED PLUMB & TRUE.
2. HYDRANT SHALL BE PAINTED FROM FACTORY.
3. HEEL TO REST IN UNDISTURBED SOIL.

4. HYDRANT ASSEMBLY MUST BE RESTRAINED TO TEE.
5. ALL FITTINGS TO BE MECHANICAL JOINT.
6. ENTIRE ASSEMBLY TO BE MECHANICALLY RESTRAINED.
7. ALL HYDRANTS ARE TO UTILIZE ANCHOR COUPLINGS, WHEN APPLICABLE.

### TYPICAL FIRE HYDRANT ASSEMBLY



**STANDARD UTILITY DETAILS**  
**City of Stuart Public Works Department**  
 121 S.W. Flagler Avenue, Stuart, Florida 34994  
 (772) 288-5300

### **TYPICAL FIRE HYDRANT ASSEMBLY**

DATE: OCTOBER 2016  
 FILE NAME: 2016 COS Std Details.dwg

SHEET NUMBER  
**25**