


1. HYDRANT SHALL BE INSTALLED PLUMB & TRUE.
2. HYDRANT SHALL BE PAINTED FROM FACTORY.
3. FOOT TO REST IN UNDISTURBED SOIL.
4. HYDRANT ASSEMBLY MUST BE RESTRAINED TO TEE.

5. ALL FITTINGS TO BE MECHANICAL JOINT.
6. ENTIRE ASSEMBLY TO BE MECHANICALLY RESTRAINED.
7. ALL HYDRANTS ARE TO UTILIZE ANCHOR COUPLINGS, WHEN APPLICABLE.



STANDARD UTILITY DETAILS
 City of Stuart
 Utilities & Engineering Department

121 S.W. Flagler Avenue, Stuart, Florida 34994

FIRE HYDRANT ASSEMBLY

DATE: OCTOBER 2021

FILE NAME: 2021 COS Std Details.dwg

SHEET NUMBER

26