


NOTE:

1. ADD LAMINATED SIGN NOTING THAT "TESTING IS IN PROGRESS - DO NOT DISTURB" WHILE SAMPLE POINT IS IN SERVICE.
2. AFTER TESTING, REMOVE THE 1" PE LINE AND CAP WITH BRASS PLUG/CAP AT CORPORATION STOP.



STANDARD UTILITY DETAILS
 City of Stuart
 Utilities & Engineering Department
 121 S.W. Flagler Avenue, Stuart, Florida 34994

BACTERIOLOGICAL SAMPLE POINT

DATE:	OCTOBER 2021	SHEET NUMBER
FILE NAME:	2021 COS Std Details.dwg	29