


PLAN



PROFILE

NOTES:

1. LANDSCAPING REQUIRED PER CITY OF STUART ORDINANCE. NO PLANTS OR TREES WITHIN 18" AROUND METER OR BACKFLOW. NO SOLDER JOINTS. MUST BE SCREENED, NO GROW IN PERIOD.
2. ASSEMBLY TO BE 18" FROM FINISH GRADE TO CENTERLINE OF THE 90° BEND.
3. RECLAIMED WATER METER ASSEMBLY MUST BE PAINTED PANTONE PURPLE 522.
4. NO SOLDER JOINTS.

**1.5" & 2" POTABLE / RECLAIMED
WATER METER & BACKFLOW
PREVENTER ASSEMBLY SERVICE
(COMMERCIAL)**



STANDARD UTILITY DETAILS
City of Stuart Public Works Department
 121 S.W. Flagler Avenue, Stuart, Florida 34994
 (772) 288-5300

**TYPICAL BACKFLOW
PREVENTER ASSEMBLY**

DATE: OCTOBER 2016
 FILE NAME: 2016 COS Std Details.dwg

SHEET NUMBER
30