



PLAN VIEW

NOTES:

1. ALL PIPE AND FITTINGS SHALL BE CLASS 53 DUCTILE IRON.
2. ALL UNDERGROUND FITTINGS SHALL BE RESTRAINED MECHANICAL JOINT TYPE & ALL ABOVE GROUND FITTINGS SHALL BE FLANGE JOINTS, FULL FACE NEOPRENE GASKETS WITH STAINLESS STEEL BOLTS.
3. METER BY-PASS TO BE HALF THE SIZE OF SERVICE SIDE ASSEMBLY (POTABLE WATER SERVICE ONLY).
4. METER BY-PASS TO BE SAME SIZE AS SUPPLY TO METER (POTABLE WATER SERVICE WITH FIRE SERVICE).
5. 12" MIN. / 16" MAX. CLEARANCE IS REQUIRED FROM THE TOP OF THE CONCRETE PAD TO THE BOTTOM OF THE RELIEF VALVE.
6. ASSEMBLY MUST BE SCREENED. LANDSCAPING MUST SCREEN AT PLANT HEIGHT, NO GROW IN PERIOD. A 18" CLEAR ZONE SHALL BE MAINTIANED AROUND ASSEMBLY.
7. ALL SPOOL PIECES TO BE @ LEAST 18" IN LENGTH.
8. PROVIDE CHAINS & LOCKS FOR THE VALVES AS REQUIRED BY THE UTILITY.
9. OS&Y GATE VALVES NEEDED IF SERVICES FIRE SYSTEM.



STANDARD UTILITY DETAILS
 City of Stuart Public Works Department
 121 S.W. Flagler Avenue, Stuart, Florida 34994
 (772) 288-5300

TYPICAL BACKFLOW PREVENTER ASSEMBLY

DATE: OCTOBER 2016
 FILE NAME: 2016 COS Std Details.dwg

SHEET NUMBER
31