


SERVICE CONNECTIONS
(SINGLE & DOUBLE)

NOTES:

1. INVERT OF LATERAL TO BE 36" FROM FINISHED GRADE EXCEPT ON "WATER LINE SIDE" OF STREET R/W WHERE IT SHALL DROP TO 48" AS SOON AS DEPTH OF SEWER MAIN PERMITS.
2. THIS DETAIL TO BE USED WHEN TOP OF SEWER MAIN IS LESS THAN 7'-0" DEEP.



STANDARD UTILITY DETAILS
City of Stuart
Utilities & Engineering Department

121 S.W. Flagler Avenue, Stuart, Florida 34994

SERVICE CONNECTION

DATE: OCTOBER 2021

FILE NAME: 2021 COS Std Details.dwg

SHEET NUMBER

43