


OPTIONS:

- 1. TANKS INSIDE BUILDING AS IS.
- 2. OUTSIDE BUILDING.
  - a. ABOVE SURFACE WATER
  - b. POST PROTECTION FROM TRAFFIC

NOTES:

- 1. ALL PIPING SHALL BE MINIMUM OF 6".
- 2. PIPING SHALL BE INSTALLED USING A CONCRETE MANHOLE ADAPTER.
- 3. SANITARY 'T' SHALL BE INSTALLED 4" INSIDE MANHOLE WALLS.
- 4. SECTIONS SHALL BE JOINED AND SEALED WITH MINIMUM 1-3/4" "RAM-NEK" SEALER OR EQUIVALENT TO FORM A WATER TIGHT SEAL.
- A. WALLS & BOTTOM SLABS MINIMUM 4" THICK REINFORCED CONCRETE.



**STANDARD UTILITY DETAILS**  
**City of Stuart**  
**Utilities & Engineering Department**

121 S.W. Flagler Avenue, Stuart, Florida 34994

**LINT TRAP**

DATE: OCTOBER 2021  
 FILE NAME: 2021 COS Std Details.dwg

SHEET NUMBER  
**47**