



NOTES:

1. ELECTRIC METER AND PRIMARY DISCONNECT MOUNTED ON BACK SIDE OF PANEL.
2. EMERGENCY GENERATOR RECEPTACLES: PYLE NATIONAL JRE 4100 (100 amp), 2044FR (200 amp).
3. ALL POWER AND CONTROLS LINES SHALL BE CONTINUOUS (NO SPLICES).
4. POWER SUPPLY MECHANICALLY INTERLOCKED.
5. GROUND FAULT INTERRUPTER ON CONVENIENCE RECEPTACLE.
6. CONTROL PANEL SHALL BE UL LISTED AS A UNIT.
7. TELEMETRY CONDUIT SHALL BE INSTALLED BY THE CONTRACTOR WITH SWEEP 90 DEGREE BEND.
8. ALL HARDWARE, NUTS & BOLTS, AND APPURTENANCES ABOVE GROUND SHALL BE 316 STAINLESS STEEL.
9. TCU FOR DATA FLOW MOUNTED INSIDE PANEL.

TYPICAL L/S CONTROL PANEL



STANDARD UTILITY DETAILS
City of Stuart Public Works Department
 121 S.W. Flagler Avenue, Stuart, Florida 34994
 (772) 288-5300

**TYPICAL
 L/S CONTROL PANEL**

DATE: OCTOBER, 2016
 FILE NAME: 2016 COS Std Details.dwg

SHEET NUMBER
56