


SECTION "C-C"

PIPE DIA.	PILE SIZE	DIMENSIONS	
		A	B
4"	12"x12"	16"	16"
8"	12"x12"	20"	16"
12"	12"x12"	26"	16"
16"	12"x12"	30"	16"

NOTE:

ALL HARDWARE SHALL BE STAINLESS STEEL.



STANDARD UTILITY DETAILS
City of Stuart
Utilities & Engineering Department
 121 S.W. Flagler Avenue, Stuart, Florida 34994

PILE CAP SUPPORT

DATE: OCTOBER 2021
FILE NAME: 2021 COS Std Details.dwg

SHEET NUMBER
68